



Stead RC Lead in Water Test Results

FY21 Filter Test

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 006535	5/29/2020	5/29/2021	2	Cooler	In hallway adjacent to restrooms	WF-05292020-006535	3/25/2021	FT-FY21-032021-006535-A	<1	FT-FY21-032021-006535-B	<1
WS- 006537	5/29/2020	5/29/2021	1	Cooler	In computer room	WF-05292020-006537	3/25/2021	FT-FY21-032021-006537-A	<1	FT-FY21-032021-006537-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 006536	3/18/2021	3/18/2022	2	Food Prep Sink	In kitchen	WF-03182021-006536	3/25/2021	FT-FY21-032021-006536-A	<1	FT-FY21-032021-006536-B	<1